

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-10-01-04-02

**Product:** „Laminate floor covering D1416 WG, 8 mm with Antistatic-Overlay U8505“

**Manufacturer:** Kronospan Schweiz AG  
Willisauerstrasse 37  
6122 Menznau  
Switzerland

**Order:** Classification of the electrostatic behaviour according to  
EN 14041:2008

**Test method:** Test of the body voltage according to EN 1815:1997

**Test report:** No. 279432 from 2009-12-21

**Test result:** The measured body voltage at 23 °C / 25 % humidity were  $\leq 2$  kV.  
The „Laminate floor covering D1416 WG, 8 mm with Antistatic-Overlay U8505“  
fulfils the criterions for the classification as an  
**“Antistatic Floor Covering”**  
in accordance with the European Standard EN 14041:2008

Dresden, 4 January 2010



Head of laboratory





Engineer in charge